

**MAINE HEALTH AND ENVIRONMENTAL TESTING LABORATORY - Visit our Web Site at: <http://www.maine.gov/dhs/etl>  
 221 State Street, Station #12 Department of Human Services Augusta, Maine 04333 Tel. No. 207-287-1716 Fax. No. 207-287-6832**

Continued from Previous Page

**Lab Sample#:** 2003721-01

**Sample Address:**

**Sample Matrix:** DW-H2O

**Sample Point:** TP-2

**Surface:**

**Description:** AFTER TREATMENT & BEFORE DISTRIBUTION EP (TOWN FARM V

**Sample Date:** 04/23/2020

**Sample Time:** 09:05:00

<u>Test (Method)/Analyte</u>	<u>Result</u>	<u>Unit</u>	<u>Qualifiers</u>	<u>MCL</u>	<u>RL</u>	<u>High Limit</u>	<u>Low Limit</u>	<u>Analysis Date</u>	<u>Analyst</u>
Color (L-10-308-00-1-A)	<5	PCU		15	5			04/23/2020 14:55:01	M.C.
<i>DW_Anions_IC (300.0)</i>									
Sulfate	5	mg/L		250				04/23/2020 15:07:00	M.C.
Fluoride	<0.1	mg/L		4	0.1			04/23/2020 15:07:00	M.C.
Chloride	9	mg/L		250				04/23/2020 15:07:00	M.C.
Nitrite Nitrogen	<0.05	mg/L			0.05			04/23/2020 15:07:00	M.C.
Nitrate Nitrogen	0.09	mg/L		10	0.05			04/23/2020 15:07:00	M.C.
<i>METALS_200.8 (200.8)</i>									
Total Hardness	25	mg/L			0			04/28/2020 10:18:00	C.S.
Antimony	<0.5	ug/L		6	0.5			04/28/2020 10:18:00	C.S.
Arsenic	<1	ug/L		10				04/28/2020 10:18:00	C.S.
Barium	0.0043	mg/L		2	0.0005			04/28/2020 10:18:00	C.S.
Beryllium	<0.5	ug/L		4	0.5			04/28/2020 10:18:00	C.S.
Cadmium	<0.5	ug/L			0.5			04/28/2020 10:18:00	C.S.
Calcium	8.0	mg/L			0.05			04/28/2020 10:18:00	C.S.
Chromium	<0.0005	mg/L		.1	0.0005			04/28/2020 10:18:00	C.S.
Copper	0.040	mg/L		1.3	0.0005			04/28/2020 10:18:00	C.S.
Iron	0.099	mg/L		.3	0.05			04/28/2020 10:18:00	C.S.
Lead	0.90	ug/L		15	0.5			04/28/2020 10:18:00	C.S.
Magnesium	1.1	mg/L			0.05			04/28/2020 10:18:00	C.S.
Manganese	0.034	mg/L		.05	0.0005			04/28/2020 10:18:00	C.S.
Mercury	<0.1	ug/L			0.1			04/28/2020 10:18:00	C.S.
Nickel	<0.0005	mg/L		0.02	0.0005			04/28/2020 10:18:00	C.S.
Selenium	<0.001	mg/L		0.05	0.001			04/28/2020 10:18:00	C.S.
Silver	<0.0005	mg/L		.1	0.0005			04/28/2020 10:18:00	C.S.
Sodium	6.4	mg/L			0.05			04/28/2020 10:18:00	C.S.
Thallium	<0.0005	mg/L		.002	0.0005			04/28/2020 10:18:00	C.S.
Uranium	<0.5	ug/L		30	0.5			04/28/2020 10:18:00	C.S.
Zinc	0.021	mg/L		5	0.001			04/28/2020 10:18:00	C.S.
pH (4500-H+B)	6.7	S.U.		8.5		8.5	6.5	04/24/2020 12:09:00	A.B.
Turbidity (180.1)	2.4	NTU				0.6		04/24/2020 08:52:00	A.B.